

FAX MEMORANDUM

Mr. Mario Stavale
McDonnell Douglas
08/08/96
Page 3

- Base Board/Cove Base
- Stucco Plasters

ND

ND

A few samples of fire door insulation were collected and found to contain no detectable asbestos. Because of time limitations and the disclosure of asbestos containing fire door insulation in the original report, it is recommended that at a minimum, the fire doors noted in the original report be treated as such.

Hard copy analytical data should be available tomorrow afternoon. I will keep you updated as to availability and any changing developments.